

The Pempek OBP Mining PLC I.S. I/O Module provides intrinsically safe (Group I Ex ib) input and output resources in a single, compact unit.

A unique fibre-optic communications interface means that the module and dedicated I.S power supply can be conveniently segregated into its isolated zone.

The fibre-optic link between the module and an Pempek OBP processor module provides real-time control and monitoring of all I/O points.

This solution is ideal for mobile mining equipment where limited installation space must be managed.

Uniquely Keyed Type Connectors to prevent incorrect machine installation.

The module is Dual Pempek OBP Type which complies with AS/NZS 4240 standard.

As per standard, every output includes two switches A&B in series with monitoring feedbacks from both.

Extra safety is achieved by using two potted boards where each includes main and watchdog processors monitoring the correctness of executed main software code.

Module Primary board - A21_B0L3P Module Secondary board - A19 A20 B0L3J



Mounting options can vary depending on customer requirements.

Specifications

- Module Type: Intrinsically Safe Input / Output with Display
- Supply: 12VDC (+/- 10%) / 20 Watts (Max) from Approved I.S. Power Supply
- Data Communications: CAN interface over Pempek OBP Fibre
- Operating Temperature: -20°C to +85°C all industrial components
- Inputs 1: 24 x I.S. Digital Inputs (12VDC)
- Inputs 2: 16 x I.S. Analog Inputs (4-20 mA)
- Inputs 3: 16 x I.S. Namur Inputs
- Outputs 1: 8 x Proportional Solenoid Outputs 0-350mA
- Outputs 2: 1 x Proportional Output 0-900mA (Requires 3 links installed in plug A21)
- Connector 1: Pempek OBP Fibre
- Connector 2: Pempek OBP A21 (12VDS I.S Supply and Solenoid Outputs)
- Connector 3: Pempek OBP A19 (12VDC I.S. Supply and Namur Inputs)
- Connector 4: Pempek OBP A20 (Digital Inputs and Analog Inputs)

Heavy Duty Enclosure

- Electroless Nickel Plated
- Rugged Construction

Mass


• 6.5kg (14.3lb)

Datasheet-L0MU0101

© Pempek 1985 – 2024

www.pempek.world | sales@pempek.world | 3/13 Hoyle Ave Castle Hill NSW 2154 | +61 02 8853 4800







Display Diagnostics

The integral 4 characters LED Matrix display provides the end-user with some basic diagnostics as to the operation of the module. These messages are as follows:

Message Explanation Result

ON

Omni Flashing Indicates nominal operation and signifies that CAN communications have been established with a host. Normal Operation Permitted

CAN

This indicates CAN Communication has not been established or has been lost. Outputs Disabled

FFRK

This indicates that internal is NOT congruent with requested outputs. This typically occurs when output has been requested but has failed to operate indicating a supply failure or wiring error. Outputs Disabled

SHRT

This indicates that a short-circuit condition has been detected as a requested output. This short-circuit could be external (most probable) or internal Outputs Disabled

OPEN

This indicates that the requested output is not drawing sufficient current to operate as expected indicating that the solenoid coil is an open circuit. Outputs Disabled

LOAD

This indicates that the requested output is not drawing current as requested when commanded to operate proportionally. Outputs Disable





CONNECTOR A19

Number	Unit / PCB GMCT50F Female	L0MU0101
	GMCT50F Female Board Mount PIN	Name
1	A	SUPPLY-PROX-SW-1
2	В	ANALOG-1
3	С	SUPPLY-PROX-SW-2
4	D	ANALOG-2
5	Е	SUPPLY-PROX-SW-3
6	F	ANALOG-3
7	Н	
8	J	
9	K	SUPPLY-PROX-SW-4
10	L	ANALOG-4
11	M	
12	N	
13	Р	SUPPLY-PROX-SW-5
14	R	ANALOG-5
15	S	
16	T	
17	U	SUPPLY-PROX-SW-6
18	V	ANALOG-6
19	W	SUPPLY-PROX-SW-7
20	X	ANALOG-7
21	Y	SUPPLY-PROX-SW-8
22	Z	ANALOG-8
23	a	
24	b	CLIDDLY DDOY CW O
25	C	SUPPLY-PROX-SW-9
26 27	d	ANALOG-9
28	e f	
29	h	SUPPLY-PROX-SW-10
30	i	ANALOG-10
31	k	71171200 10
32	m	
33	n	SUPPLY-PROX-SW-11
34	р	ANALOG-11
35	r	SUPPLY-PROX-SW-12
36	S	ANALOG-12
37	t	SUPPLY-PROX-SW-13
38	U	ANALOG-13
39	٧	
40	W	
41	Х	SUPPLY-PROX-SW-14
42	У	ANALOG-14
43	Z	
44	AA	
45	ВВ	SUPPLY-PROX-SW-15
46	CC	ANALOG-15
47	DD	SUPPLY-PROX-SW-16
48	EE	ANALOG-16
49	FF	OVIS
50	HH	12VIS





Image depict coding pins required



CONNECTOR A20

Number	Unit / PCB GMST50F Female Board Mount PIN	L0MU0101
	PIN	Name
1	Α	INP1
2	В	INP2
3	С	INP3
4	D	INP4
5	Е	INP5
6	F	INP6
7	Н	INP7
8	J	INP8
9	K	INP9
10	L	INP10
11	M	INP11
12	N	INP12
13	P	INP13
14	R	INP14
15	\$	INP15
16	T	INP16
17	U	INP17
18	V	INP18
19	W	INP19
20	X	INP20
21	Y	INP21
22	Z	INP22
23 24	a h	INP23
	b	INP24
25 26	c d	MODULE SELECT A
27		MODULE SELECT-4
28	e f	MODULE SELECT-3
29	h	MODULE SELECT-5
30	i	MODULE SELECT-2
31	k	MODULE SELECT 2
32	m	MODULE SELECT-1
33	n	AN17
34		AN18
35	p r	AN19
36	S	AN20
37	†	AN21
38	U	AN22
39	V	AN23
40	W	AN24
41	X	AN25
42	У	AN26
43	Z	AN27
44	AA	AN28
45	BB	AN29
46	CC	AN30
47	DD	AN31
48	EE	AN32
49	FF	
50	HH	OVIS
30	1.0.1	0.110





Image depict coding pins required

© Pempek 1985 – 2024



LOMU0101 Pempek OBP Proportional Solenoid Ex ib Intrinsically Safe I/O Analog and Namur Inputs Type A

CONNECTOR A21 - Proportional Solenoids 8x 0-350mA variant

Number	Unit / PCB	L0MU0101
	VMCT-34F Female Board Mount PIN	Name
1	A	
2	В	PROP-SOL-1
3	С	
4	D	PROP-SOL-1 Return OVIS
5	Е	
6	F	PROP-SOL-2
7	Н	
8	J	PROP-SOL-2 Return OVIS
9	K	
10	L	PROP-SOL-3
11	М	MODULE SELECT-1
12	N	PROP-SOL-3 Return OVIS
13	Р	
14	R	PROP-SOL-4
15	S	MODULE SELECT-2
16	T	PROP-SOL-4 Return OVIS
17	U	
18	V	PROP-SOL-5
19	W	MODULE SELECT-3
20	Χ	PROP-SOL-5 Return OVIS
21	Υ	
22	Z	PROP-SOL-6
23	AA	MODULE SELECT-4
24	ВВ	PROP-SOL-6 Return OVIS
25	CC	
26	DD	PROP-SOL-7
27	EE	
28	FF	PROP-SOL-7 Return OVIS
29	HH	
30	JJ	PROP-SOL- 8
31	KK	
32	LL	PROP-SOL-8 Return OVIS
33	MM	OVIS Supply
34	NN	12VIS Supply





Image depict coding pins required



CONNECTOR A21 Proportional Solenoid 0-900mA variant

Number	Unit / PCB	L0MU0101
	VMCT-34F Female Board Mount PIN	Name
1	A	A-C Link1 in A21 Plug
2	В	PROP-SOL-1
3	С	A-C Link1 in A21 Plug
4	D	PROP-SOL-1 Return OVIS
5	Е	E-H Link2 in A21 Plug
6	F	
7	Н	E-H Link2 in A21 Plug
8	J	
9	K	K-P Link3 in A21 Plug
10	L	
11	M	MODULE SELECT-1
12	N	
13	P	K-P Link3 in A21 Plug
14	R	
15	S	MODULE SELECT-2
16	T	
17	U	
18	V	
19	W	MODULE SELECT-3
20	Χ	
21	Υ	
22	Z	
23	AA	MODULE SELECT-4
24	ВВ	
25	CC	
26	DD	
27	EE	
28	FF	
29	HH	
30	JJ	
31	KK	
32	LL	
33	MM	OVIS Supply
34	NN	12VIS Supply





Image depict coding pins required



Fibre Optic Patch Cables

Part Number	Description
H0LW0401	Fibre Optic Patch ST-ST Multi-Mode
H0M10101	Connector Assembly Fibre 8 way 7m
H0M10201	Connector Assembly Fibre 8 way 10m
H0M10301	Connector Assembly Fibre 8 way 1m
H0M10401	Connector Assembly Fibre 8 way 4m
H0M10801	Connector Assembly Fibre 8 way 8m
H0M10901	Connector Assembly Fibre 8 way 11m
H0M11001	Fibre Optic Patch Assembly 8 way 3m
H0M11201	Connector Assembly Fibre 8 way 12.5m

Specifications

Product Type: Pre-manufactured cable assembly
 Construction: Flbre Optic with ST terminations

Connector 1 : Fibre Optic Tx
Connector 2: Fibre-optic Rx
Pin Type: ST Fibre Plugs

Conductor Type: Multi-mode Fibre-optic

• Insulation Rating: N/A

• Temperature Rating: $-40^{\circ \text{C}}$ to $85^{\circ \text{C}}$



Image above Fibre Optic Patch ST-ST Multi-Mode

Connector Assembly

Part Number	Description
H0LW0201	Connector Assembly A19 2.2m
H0LW0301	Connector Assembly A20 2.2m
H0LW0901	Connector Assembly A20 5m
H0LW0902	Connector Assembly A20 1.5m
H0LW0903	Connector Assembly A20 Fully Populated 1.5m
H0LZ0501	Connector Assembly A21 2.2m
H0LZ0502	Connector Assembly A21 1.5m
H0LZ0503	Connector Assembly A21 1.5m Fully Populated



Specifications

Product Type: Pre-manufactured cable assembly
 Construction: Connector with flying leads (pigtail)

• **Pin Type:** Male (Gold-plated)

Conductor Type: PVDF Tinned Stranded Wire

Insulation Rating: 600 volts

Temperature Rating: -65 to 105 C

• **Recommended Tools:** PVDF / Teflon Insulation Stripping Tool

Cable options can vary depending on customer requirements.